

Attestation

BREEAM[®]

On 4 September 2020, Eurofins Product Testing A/S received a sample of a chemical anchor with the product name:

FIS V Zero

supplied by

Fischerwerke GmbH & Co. KG

The sample was supplied as being representative of the manufactured product, and it has been tested as in accordance with the relevant EN 16516, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ASTM D2369 testing standards (See test report no. 392-2020-00381501_A_EN_rev1 and 392-2020-00381502_XG_EN).

The test results of the tested sample indicate that the product qualifies for the below mentioned BREEAM specifications on VOC emissions and VOC content by complying with:

- **BREEAM[®] International: Compliance with Exemplary criteria on both VOC emission and VOC content** of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor Air Quality (version SD233 issue 2.0 of July 2017)
- **BREEAM[®] UK: Compliance with Exemplary criteria on both VOC emission and VOC content** of BREEAM UK: New Construction 2018, Technical Manual: Hea 02 Indoor Air Quality (version SD5078 issue 3.0 of July 2019)

21 October 2021



Rasmus Verdier
Analytical Service Manager



Pernille Krintel
Analytical Service Manager